

English

Instruction and Operation Manual

S415 OEM

Compact Thermal Mass Flow Meter (Eco-Inline)



.550

Dear Customer,

Thank you for choosing our product.

Before you start up the device please read the operating instructions in full and carefully observe them. The manufacturer cannot be held liable for any damage which occurs as a result of non-observance or noncompliance with this manual.

Should the device be tampered with in any manner other than a procedure which is described and specified in the manual, the warranty is canceled and the manufacturer is exempt from liability.


The device is destined exclusively for the described application.

SUTO offers no guarantee for the suitability for any other purpose. SUTO is also not liable for consequential damage resulting from the delivery, capability or use of this device.

Table of Contents

2 Registered Trademarks.63 RF Exposure Information and Statement.74 Application.85 Features.86 Technical Data.96.1 General Data.96.2 Electrical Data.106.3 Output Signals.106.4 Accuracy107 Dimensional Drawing.118 Installation.148.1 Installation Considerations.148.2 LED Indicators.158 3 Electrical Connection159 Signal Outputs.179.1 Analog Output.179.2 Pulse Output.179.3 Modbus Interface.189.3.1 Modbus Information189.3.2.2 Modbus/RTU Cable Length.199.3.2.3 Create Daisy-Chain using RS-485 Splitter.219.3.2.4 Topology of Modbus/RTU Daisy-Chain.239.5 Connection between S415 OEM Outputs and Customer Equipment2410 Configuration.239.5 Connection between S415 OEM Outputs and Customer Equipment2410 Configuration.2611 Calibration.2712 Disposal or Waste.2713 Appendix A - Specifications.2813.1 Flow Ranges.2813.2 Error Code.29	1 Safety Instructions	4
3 RF Exposure Information and Statement. 7 4 Application. 8 5 Features. 8 6 Technical Data. 9 6.1 General Data. 9 6.2 Electrical Data 10 6.3 Output Signals. 10 6.4 Accuracy 10 7 Dimensional Drawing. 11 8 Installation 14 8.1 Installation Considerations. 14 8.2 LED Indicators. 15 8.3 Electrical Connection 15 9 Signal Outputs. 17 9.1 Analog Output. 17 9.2 Pulse Output. 17 9.3.1 Modbus Interface. 18 9.3.2 Connect Several S415 OEM to Modbus Master 19 9.3.2.2 Modbus/RTU Cable Length. 19 9.3.2.3 Create Daisy-Chain using RS-485 Splitter. 21 9.3.2.4 Topology of Modbus/RTU Daisy-Chain. 23 9.4 M-Bus Output. 23 9.5 Connection between S415 OEM Outputs and Customer Equipment 24 10 Configuration. 26 11 Calibration. 27 12 Disposal or Waste. 27 13	2 Registered Trademarks	6
4 Application 8 5 Features 8 6 Technical Data 9 6.1 General Data 9 6.2 Electrical Data 10 6.3 Output Signals 10 6.4 Accuracy 10 7 Dimensional Drawing 11 8 Installation 14 8.1 Installation Considerations 14 8.2 LED Indicators 15 8.3 Electrical Connection 15 9 Signal Outputs 17 9.1 Analog Output 17 9.3 Modbus Interface 18 9.3.1 Modbus Information 18 9.3.2 Connect Several S415 OEM to Modbus Master 19 9.3.2.1 Modbus/RTU Cable Length 19 9.3.2.3 Create Daisy-Chain using RS-485 Splitter 21 9.3.2.4 Topology of Modbus/RTU Daisy-Chain 22 9.4 M-Bus Output 23 9.5 Connection between S415 OEM Outputs and Customer Equipment 24 10 Configuration 26 11 Calibration 27 12 Disposal or Waste 27 13 Appendix A - Specifications 28 13.1 Flow Ranges		
5 Features. 8 6 Technical Data. 9 6.1 General Data. 9 6.2 Electrical Data. 10 6.3 Output Signals. 10 6.4 Accuracy 10 7 Dimensional Drawing. 11 8 Installation 14 8.1 Installation Considerations. 14 8.2 LED Indicators. 15 8.3 Electrical Connection 15 9 Signal Outputs. 17 9.1 Analog Output. 17 9.3 Modbus Interface. 18 9.3.1 Modbus Information. 18 9.3.2 Connect Several S415 OEM to Modbus Master. 19 9.3.2.1 Modbus/RTU Cable Length. 19 9.3.2.1 Modbus/RTU Wiring and Cable Type. 20 9.3.2.3 Create Daisy-Chain using RS-485 Splitter. 21 9.3.2.4 Topology of Modbus/RTU Daisy-Chain. 22 9.4 M-Bus Output. 23 9.5 Connection between S415 OEM Outputs and Customer Equipment 24 10 Configuration. 26 11 Calibration. 27 12 Disposal or Waste. 27 13 Appendix A - Specifications. 28		
6.1 General Data. 9 6.2 Electrical Data. 10 6.3 Output Signals. 10 6.4 Accuracy 10 7 Dimensional Drawing. 11 8 Installation 14 8.1 Installation Considerations. 14 8.2 LED Indicators. 15 8.3 Electrical Connection 15 9 Signal Outputs. 17 9.1 Analog Output. 17 9.2 Pulse Output. 17 9.3 Modbus Interface. 18 9.3.1 Modbus Information. 18 9.3.2 Connect Several S415 OEM to Modbus Master. 19 9.3.2.1 Modbus/RTU Cable Length. 19 9.3.2.3 Create Daisy-Chain using RS-485 Splitter. 21 9.3.2.4 Topology of Modbus/RTU Daisy-Chain. 22 9.4 M-Bus Output. 23 9.5 Connection between S415 OEM Outputs and Customer Equipment 24 10 Configuration. 27 12 Disposal or Waste. 27 13 Appendix A - Specifications. 28 13.1 Flow Ranges. 28 13.2 Error Code. 29	5 Features	8
6.2 Electrical Data.106.3 Output Signals.106.4 Accuracy107 Dimensional Drawing.118 Installation.148.1 Installation Considerations.148.2 LED Indicators.158.3 Electrical Connection159 Signal Outputs.179.1 Analog Output.179.2 Pulse Output.179.3 Modbus Interface.189.3.1 Modbus Information.189.3.2 Connect Several S415 OEM to Modbus Master.199.3.2.3 Create Daisy-Chain using RS-485 Splitter.219.3.2.4 Topology of Modbus/RTU Daisy-Chain.229.4 M-Bus Output.239.5 Connection between S415 OEM Outputs and Customer Equipment2410 Configuration.2713 Appendix A - Specifications.2813.1 Flow Ranges.2813.2 Error Code.29	6 Technical Data	9
6.3 Output Signals.106.4 Accuracy107 Dimensional Drawing.118 Installation.148.1 Installation Considerations.148.2 LED Indicators.158.3 Electrical Connection159 Signal Outputs.179.1 Analog Output.179.2 Pulse Output.179.3 Modbus Interface.189.3.1 Modbus Information.189.3.2 Connect Several S415 OEM to Modbus Master.199.3.2.3 Create Daisy-Chain using RS-485 Splitter.219.3.2.4 Topology of Modbus/RTU Daisy-Chain.229.4 M-Bus Output.239.5 Connection between S415 OEM Outputs and Customer Equipment2410 Configuration.2712 Disposal or Waste.2713 Appendix A - Specifications.2813.1 Flow Ranges.2813.2 Error Code.29	6.1 General Data	9
6.4 Accuracy107 Dimensional Drawing.118 Installation148.1 Installation Considerations.148.2 LED Indicators.158.3 Electrical Connection159 Signal Outputs.179.1 Analog Output.179.2 Pulse Output.179.3 Modbus Interface.189.3.1 Modbus Information.189.3.2 Connect Several S415 OEM to Modbus Master.199.3.2.3 Create Daisy-Chain using RS-485 Splitter.219.3.2.4 Topology of Modbus/RTU Daisy-Chain.229.4 M-Bus Output.239.5 Connection between S415 OEM Outputs and Customer Equipment2410 Configuration.2611 Calibration.2712 Disposal or Waste.2713 Appendix A - Specifications.2813.2 Error Code.29	6.2 Electrical Data	10
7 Dimensional Drawing.118 Installation148.1 Installation Considerations.148.2 LED Indicators.158.3 Electrical Connection159 Signal Outputs.179.1 Analog Output.179.2 Pulse Output.179.3 Modbus Interface.189.3.1 Modbus Information.189.3.2 Connect Several S415 OEM to Modbus Master.199.3.2.1 Modbus/RTU Cable Length.199.3.2.3 Create Daisy-Chain using RS-485 Splitter.219.3.4 Topology of Modbus/RTU Daisy-Chain.229.4 M-Bus Output.239.5 Connection between S415 OEM Outputs and Customer Equipment2410 Configuration.2611 Calibration.2712 Disposal or Waste.2713 Appendix A - Specifications.2813.2 Error Code.29		
8 Installation 14 8.1 Installation Considerations 14 8.2 LED Indicators 15 8.3 Electrical Connection 15 9 Signal Outputs 17 9.1 Analog Output 17 9.2 Pulse Output 17 9.3 Modbus Interface 18 9.3.1 Modbus Information 18 9.3.2 Connect Several S415 OEM to Modbus Master 19 9.3.2.1 Modbus/RTU Cable Length 19 9.3.2.2 Modbus/RTU Wiring and Cable Type 20 9.3.2.3 Create Daisy-Chain using RS-485 Splitter 21 9.3.2.4 Topology of Modbus/RTU Daisy-Chain 22 9.4 M-Bus Output 23 9.5 Connection between S415 OEM Outputs and Customer Equipment 24 10 Configuration 26 11 Calibration 27 12 Disposal or Waste 27 13 Appendix A - Specifications 28 13.1 Flow Ranges 28 13.2 Error Code 29		
8.1 Installation Considerations.148.2 LED Indicators.158.3 Electrical Connection159 Signal Outputs.179.1 Analog Output.179.2 Pulse Output.179.3 Modbus Interface.189.3.1 Modbus Information.189.3.2 Connect Several S415 OEM to Modbus Master.199.3.2.1 Modbus/RTU Cable Length.199.3.2.2 Modbus/RTU Wiring and Cable Type.209.3.2.3 Create Daisy-Chain using RS-485 Splitter.219.3.2.4 Topology of Modbus/RTU Daisy-Chain.229.4 M-Bus Output.239.5 Connection between S415 OEM Outputs and Customer Equipment2410 Configuration.2712 Disposal or Waste.2713 Appendix A - Specifications.2813.1 Flow Ranges.2813.2 Error Code.29		
8.2 LED Indicators.158.3 Electrical Connection159 Signal Outputs.179.1 Analog Output.179.2 Pulse Output.179.3 Modbus Interface.189.3.1 Modbus Information.189.3.2 Connect Several S415 OEM to Modbus Master.199.3.2.1 Modbus/RTU Cable Length.199.3.2.2 Modbus/RTU Wiring and Cable Type.209.3.2.3 Create Daisy-Chain using RS-485 Splitter.219.3.2.4 Topology of Modbus/RTU Daisy-Chain.229.4 M-Bus Output.239.5 Connection between S415 OEM Outputs and Customer Equipment2410 Configuration.2712 Disposal or Waste.2713 Appendix A - Specifications.2813.2 Error Code.29		
8.3 Electrical Connection159 Signal Outputs.179.1 Analog Output.179.2 Pulse Output.179.3 Modbus Interface.189.3.1 Modbus Information.189.3.2 Connect Several S415 OEM to Modbus Master.199.3.2.1 Modbus/RTU Cable Length.199.3.2.2 Modbus/RTU Wiring and Cable Type.209.3.2.3 Create Daisy-Chain using RS-485 Splitter.219.3.2.4 Topology of Modbus/RTU Daisy-Chain.229.4 M-Bus Output.239.5 Connection between S415 OEM Outputs and Customer Equipment2410 Configuration.2712 Disposal or Waste.2713 Appendix A - Specifications.2813.2 Error Code.29		
9 Signal Outputs.179.1 Analog Output.179.2 Pulse Output.179.3 Modbus Interface.189.3.1 Modbus Information.189.3.2 Connect Several S415 OEM to Modbus Master.199.3.2.1 Modbus/RTU Cable Length.199.3.2.2 Modbus/RTU Wiring and Cable Type.209.3.2.3 Create Daisy-Chain using RS-485 Splitter.219.3.2.4 Topology of Modbus/RTU Daisy-Chain.229.4 M-Bus Output.239.5 Connection between S415 OEM Outputs and Customer Equipment2410 Configuration.2611 Calibration.2712 Disposal or Waste.2713 Appendix A - Specifications.2813.1 Flow Ranges.2813.2 Error Code.29		
9.1 Analog Output.179.2 Pulse Output.179.3 Modbus Interface.189.3.1 Modbus Information.189.3.2 Connect Several S415 OEM to Modbus Master.199.3.2.1 Modbus/RTU Cable Length.199.3.2.2 Modbus/RTU Wiring and Cable Type.209.3.2.3 Create Daisy-Chain using RS-485 Splitter.219.3.2.4 Topology of Modbus/RTU Daisy-Chain.229.4 M-Bus Output.239.5 Connection between S415 OEM Outputs and Customer Equipment2410 Configuration.2611 Calibration.2712 Disposal or Waste.2713 Appendix A - Specifications.2813.1 Flow Ranges.2813.2 Error Code.29		
9.2 Pulse Output.179.3 Modbus Interface.189.3.1 Modbus Information.189.3.2 Connect Several S415 OEM to Modbus Master.199.3.2.1 Modbus/RTU Cable Length.199.3.2.2 Modbus/RTU Wiring and Cable Type.209.3.2.3 Create Daisy-Chain using RS-485 Splitter.219.3.2.4 Topology of Modbus/RTU Daisy-Chain.229.4 M-Bus Output.239.5 Connection between S415 OEM Outputs and Customer Equipment2410 Configuration.2611 Calibration.2712 Disposal or Waste.2713 Appendix A - Specifications.2813.1 Flow Ranges.2813.2 Error Code.29		
9.3 Modbus Interface.189.3.1 Modbus Information.189.3.2 Connect Several S415 OEM to Modbus Master.199.3.2.1 Modbus/RTU Cable Length.199.3.2.2 Modbus/RTU Wiring and Cable Type.209.3.2.3 Create Daisy-Chain using RS-485 Splitter.219.3.2.4 Topology of Modbus/RTU Daisy-Chain.229.4 M-Bus Output.239.5 Connection between S415 OEM Outputs and Customer Equipment2410 Configuration.2611 Calibration.2712 Disposal or Waste.2713 Appendix A - Specifications.2813.1 Flow Ranges.2813.2 Error Code.29		
9.3.1 Modbus Information189.3.2 Connect Several S415 OEM to Modbus Master199.3.2.1 Modbus/RTU Cable Length199.3.2.2 Modbus/RTU Wiring and Cable Type209.3.2.3 Create Daisy-Chain using RS-485 Splitter219.3.2.4 Topology of Modbus/RTU Daisy-Chain229.4 M-Bus Output239.5 Connection between S415 OEM Outputs and Customer Equipment2410 Configuration2611 Calibration2712 Disposal or Waste2713 Appendix A - Specifications2813.1 Flow Ranges2813.2 Error Code29		
9.3.2 Connect Several S415 OEM to Modbus Master.199.3.2.1 Modbus/RTU Cable Length.199.3.2.2 Modbus/RTU Wiring and Cable Type.209.3.2.3 Create Daisy-Chain using RS-485 Splitter.219.3.2.4 Topology of Modbus/RTU Daisy-Chain.229.4 M-Bus Output.239.5 Connection between S415 OEM Outputs and Customer Equipment2410 Configuration.2611 Calibration.2712 Disposal or Waste.2713 Appendix A - Specifications.2813.1 Flow Ranges.2813.2 Error Code.29		
9.3.2.1 Modbus/RTU Cable Length.199.3.2.2 Modbus/RTU Wiring and Cable Type.209.3.2.3 Create Daisy-Chain using RS-485 Splitter.219.3.2.4 Topology of Modbus/RTU Daisy-Chain.229.4 M-Bus Output.239.5 Connection between S415 OEM Outputs and Customer Equipment2410 Configuration.2611 Calibration.2712 Disposal or Waste.2713 Appendix A - Specifications.2813.1 Flow Ranges.2813.2 Error Code.29		
9.3.2.2 Modbus/RTU Wiring and Cable Type.209.3.2.3 Create Daisy-Chain using RS-485 Splitter.219.3.2.4 Topology of Modbus/RTU Daisy-Chain.229.4 M-Bus Output.239.5 Connection between S415 OEM Outputs and Customer Equipment2410 Configuration.2611 Calibration.2712 Disposal or Waste.2713 Appendix A - Specifications.2813.1 Flow Ranges.2813.2 Error Code.29		
9.3.2.3 Create Daisy-Chain using RS-485 Splitter.219.3.2.4 Topology of Modbus/RTU Daisy-Chain.229.4 M-Bus Output.239.5 Connection between S415 OEM Outputs and Customer Equipment2410 Configuration.2611 Calibration.2712 Disposal or Waste.2713 Appendix A - Specifications.2813.1 Flow Ranges.2813.2 Error Code.29		
9.3.2.4 Topology of Modbus/RTU Daisy-Chain229.4 M-Bus Output239.5 Connection between S415 OEM Outputs and Customer Equipment2410 Configuration2611 Calibration2712 Disposal or Waste2713 Appendix A - Specifications2813.1 Flow Ranges2813.2 Error Code29		
9.4 M-Bus Output239.5 Connection between S415 OEM Outputs and Customer Equipment		
9.5 Connection between S415 OEM Outputs and Customer Equipment		
24 10 Configuration	9.4 M-Bus Output.	23
10 Configuration2611 Calibration2712 Disposal or Waste2713 Appendix A - Specifications2813.1 Flow Ranges2813.2 Error Code29		
11 Calibration.2712 Disposal or Waste.2713 Appendix A - Specifications.2813.1 Flow Ranges.2813.2 Error Code.29		
12 Disposal or Waste	-	
13 Appendix A - Specifications.2813.1 Flow Ranges.2813.2 Error Code.29		
13.1 Flow Ranges		
13.2 Error Code29	•••••••	
	13.3 Order Table	

1 Safety Instructions



Please check if this instruction manual matches the product type.

Please observe all notes and instructions indicated in this manual. It contains essential information which must be observed before and during installation, operation, and

maintenance. Therefore this instruction manual must be read carefully by the technician as well as by the responsible user / qualified personnel.

This instruction manual must be available at the operation site of the flow meter at any time. In case of any obscurities or questions, regarding this manual or the product, please contact the manufacturer.



WARNING!

Compressed air!

Any contact with quickly escaping air or bursting parts of the compressed air system can lead to serious injuries or even death!

- Do not exceed the maximum permitted pressure range (see sensors label).
- Only use pressure tight installation material.
- Avoid that persons get hit by escaping air or bursting parts of the instrument.
- The system must be pressureless during maintenance work.



WARNING!

Voltage used for supply!

Any contact with energized parts of the product might lead to an electrical shock which can lead to serious injuries or even death!

- Consider all regulations for electrical installations.
- The system must be disconnected from any power supply during maintenance.
- Any electrical work on system is only allowed by authorized qualified personal.





ATTENTION!

Permitted operating parameters!

Observe the permitted operating parameters. Any operation exceeding this parameters can lead to malfunctions and might lead to damage on the instrument or the system.

- Do not exceed the permitted operating parameters.
- Make sure the product is operated in its permitted limitations.
- Do not exceed or undercut the permitted storage and operating temperature and pressure.
- The product should be maintained and calibrated frequently, at least annually.

General safety instructions

- It is not allowed to use the product in explosive areas.
- Please observe the national regulations before/during installation and operation.

Remarks

• It is not allowed to disassemble the product.



ATTENTION!

Measurement values can be affected by malfunction!

The product must be installed properly and frequently maintained. Otherwise it might lead to wrong measurement values, which can result in wrong results.

- Always observe the direction of the flow when installing the device. The direction is indicated on the housing.
- Do not exceed the maximum operating temperature at the sensors tip.
- Avoid condensation on the sensor element as this will affect accuracy enormously.



Storage and transportation

- Make sure that the transportation temperature is between -30 ... +70°C.
- For storage and transportation it is recommended to use the packaging which comes with the device.
- Make sure that storage temperature of the device is between -10 ... +50°C.
- Avoid direct UV and solar radiation during storage.
- For the storage the humidity must be <90% with no condensation.

2 Registered Trademarks

Trademark	Trademark owner
SUTO®	SUTO ITEC
MODBUS®	Modbus Organization, Hopkinton, USA
HART [®]	HART Communication Foundation, Austin, USA
Android™, Google Play	Google LLC

3 RF Exposure Information and Statement

This equipment complies with FCC RF radiation exposure limits set forth for an uncontrolled environment. This equipment should be installed and operated with minimum distance of 20 cm between the radiator and your body.

This device complies with part 15 of the FCC rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

NOTE: The manufacturer is not responsible for any radio or TV interference caused by unauthorized modifications to this equipment. Such modifications could void the user's authority to operate the equipment.

NOTE: This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver.
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
- Consult the dealer or an experienced radio/TV technician for help
- This device and its antenna(s) must not be co-located or operating in conjunction with any other antenna or transmitter.

4 Application

The S415 OEM is the thermal mass flow meter that is designed to measure the volumetric flow and consumption of compressed air and nitrogen within the permitted operating parameters. (See <u>Technical</u> <u>Data</u> on the next page.)

The default unit settings are: volumetric flow in l/min and total Consumption in m^3 . Other units can be configured using the mobile App S4C-FS, which can be downloaded from the Google Play store or SUTO website. For more information, see chapter <u>10</u> on page 26.

5 Features

- Inline thermal mass flow meter virtually independent of pressure and temperature changes
- Process connection G-type thread, DN8, DN15, DN20, DN25 and DN32
- Integrated flow conditioner, no need of straight inlet sections
- Very short response time
- Particularly suitable for measuring at point-of-use flow and consumption of compressed air or $\rm N_{2}$
- Integrated display showing volumetric flow
- Choices of output signals:
 - Analogue 4 ... 20 mA and pulse output
 - Modbus interface
 - M-Bus interface
- Bluetooth interface for device settings
- Configurable through the mobile phone App S4C-FS

6 Technical Data

6.1 General Data

CE FC ID: 2ASK2-SUTO-002				
Parameters	Standard unit flow: I/min (default) Consumption units: m ³ (default)			
Reference conditions	ISO1217 20°C, 1000 hPa (Standard-Unit) DIN1343 0°C , 1013.25 hPa (Norm-Unit)			
Principle of measurement	Thermal mass flow			
Sensor	Glass coated resistive sensor			
Ambient temperature /Transport temperature	0 +50°C / -30 +70°C			
Medium conditions	0 +50°C, rH<90% no condensation			
Operating pressure	0 1.0 MPa			
Pressure drop	 Maximum pressure drop at the maximum flow of the Standard (S) flow range: DN8 type : 30 hPa DN15 type: 100 hPa DN20 type: 100 hPa DN25 type: 200 hPa DN32 type: 170 hPa 			
Casing	Process connection: aluminum alloy Wetted parts: aluminum alloy Top casing: PC + ABS			
Protection class	IP54			
Dimensions	See dimensional drawing on page <u>11</u> .			
Display	4-digit LED display			
Tube diameter	DN8, DN15, DN20, DN25, and DN32			
Process connection	G inner thread ISO 228-1			
Weight	0.45 kg (DN8), 0.44 kg (DN15) 0.97 kg (DN20), 0.94 kg (DN25) 1.7 kg (DN32)			

6.2 Electrical Data

Power supply	15 30 VDC, 120 mA @ 24 VDC

6.3 Output Signals

Analogue output	Signal: 4 20 mA, isolated Scaling: 0 to max flow Max load: 250R
Pulse output	1 pulse per m ³ , isolated switch, max. 30 VDC, 200 mA (pulse length: 10 120 ms, depends on flow rate)
Modbus output	See section 9.3 on page 18.

6.4 Accuracy

Accuracy* (at 6 bar, 20°C, rH<40%)	\pm (3.0% of reading + 0.3% Full Scale)
Temperature coefficient	< 0.1%/K Full Scale
Pressure coefficient	<5% / 1 MPa
Turndown ratio	50:1
Stated accuracy at	Ambient/process temperature 23°C ± 3°C Ambient/process humidity <90% Process pressure at 0.6 MPa
Repeatability	±1% of reading
Sampling rate	3 samples per second

* The specified accuracy is valid only within the minimum and maximum flow rates that are stated in section 13.1 on page 28.


Remark:

The total consumption value is saved to the permanent memory every 5 minutes. If within these 5 minutes the device is powered off, it will restore the last consumption value which was saved in the last cycle.




Unit: mm

DN8/DN15




DN20/DN25





DN32



8 Installation

The S415 OEM is delivered with following components:

Qty.	Description	Item no.
1	S415 OEM Compact Thermal Mass Flow Meter	E695 4150 E695 4151 E695 4152 E695 4153 E695 4154
1	5 m cable with M8 connector and open ends	A553 0136
1	Instruction manual	No P/N
1	Calibration certificate	No P/N

8.1 Installation Considerations

• When installing the flow meter, always observe the arrows on the housing showing the flow direction. The air/gas flow direction must always be in line with the arrows on the housing.




- Due to the integrated flow conditioner, there are no additional straight pipe requirements for good measurement. However for best measurement, it is recommended 3-5 times inner diameter straight pipe at the inlet.
- The S415 OEM can be installed in horizontal or vertical pipes.

Note:

- The device is for indoor use only! For outdoor applications, ensure a protection from solar radiation and rain. Always observe operating temperature and humidity as stated in the the technical data.
- It is strongly recommend not to install S415 OEM permanently in wet air/gas conditions, which exists usually right after a compressor outlet.

8.2 LED Indicators

The S415 OEM provides two LED indicators on the display panel, which indicate the status of display and Bluetooth connection separately.



LED	Function	Status
lpm	Indicator for the display state (volumetric flow)	On: The display is showing the volumetric flow rate. Flashing: N/A
stat.	Indicator for the Bluetooth state	On: The Bluetooth is connected. Flashing: N/A

8.3 Electrical Connection

The flow meter comes with two connector plugs "A" and "B". By default the flow meter is delivered with one 5 m cable with a M8 connector on one side and open wires on the other side. To make the S415 OEM work, one cable connection is sufficient. However, if the pulse output is to be used or the supply and the signal need to be on separate cables, a second connection cable must be ordered.



		Legend	to pin assignment
		GND _M	Ground for Modbus
	(3 4)	-V _B	Negative supply voltage
		+V _B	Positive supply voltage
B		+I	Positive 4 20 mA signal (isolated)
		-I	Negative 4 20 mA signal (isolated)
		D+	Modbus data +
00		D-	Modbus data -
		SW	Isolated pulse output (switch)
		M-Bus	M-Bus data
		NA	Not Applicable

Pin assignment connector plug M8

Output type	Connector	Pin 1	Pin 2	Pin 3	Pin 4
Madhua	А	D-	-V _B	+V _B	D+
Modbus	В	D-	GND_{M}	NA	D+
Dulce and analog	А	-I	-V _B	+V _B	+I
Pulse and analog	В	-I	SW	SW	+I
M. Due	А	M-Bus	-V _B	+V _B	M-Bus
M-Bus	В	M-Bus	NA	NA	M-Bus
Wire co	lor	Brown	White	Blue	Black



ATTENTION!

Do not screw the M8 plug using force. Otherwise, it may damage the connecting pins.


9 Signal Outputs

9.1 Analog Output

The flow meter has an analog output of 4 \dots 20 mA. This output can be scaled to match a desired measuring range. Standard scaling is from 0 to the max flow. The corresponding flow in different pipe sizes can be found in section <u>13.1</u> on page 28.

9.2 Pulse Output

The flow meter outputs one pulse per a consumption unit. This pulse output can be connected to an external pulse counter to count the total consumption. The number of m³ per second are summed up and indicated after one second. Pulse length depends on flow rate.



Volumetric flow [m³/s]	Volumetric flow [m³/h]	Pulse length [ms]	Max. pulse output per hour
≦ 3	≦ 10800	120	1080
> 3	> 10800	60	2880
> 6	> 21600	30	3960

9.3 Modbus Interface

9.3.1 Modbus Information

The default settings of the Modbus interface are as follows:

Mode	RTU
Baud rate	19200
Device address	Last two digits of the serial number
Framing / parity / stop bit	8, N, 1
Response timeout	1 second
Response delay	0 ms
Inter-frame spacing	7 char

Response message that the device returns to the master:

• Function code: 03

The information of the byte order is shown in the table below:

Byte		Data				
Order	1st	2nd	3rd	4th	Туре	
1-0-3-2	Byte 1 (MMMMMMMM*)	Byte 0 (MMMMMMMM *)	Byte 3 (SEEEEEE)	Byte 2 (EMMMMMMM *)	FLOAT	
1-0-3-2	Byte 1	Byte 0 LSB	Byte 3 MSB	Byte 2	UINT32 INT32	
1-0	Byte 1 MSB	Byte 0 LSB			UINT16 INT16	
1-0	Byte 1 XXX *	Byte 0 DATA			UINT8 INT8	

* S: Sign, E: Exponent, M: Mantissa, XXX: no value

Note: Modbus communication settings as well as other settings can be changed by the service App **S4C-FS** or through the windows based **Service Software**.

Channel name	Resolution	Format	Length	Register address
Flow	0.1	FLOAT	4-Byte	6
Consumption	1	UNIT32	4-Byte	8

Available measurement channels

9.3.2 Connect Several S415 OEM to Modbus Master

The S415 OEM with Modbus/RTU interface can be easily daisy-chained to a Modbus Master device. This master can be either SUTO displays and gateways or any third-party Modbus/RTU master.


Through this method you can add up to 16 flow meters to the master device.

9.3.2.1 Modbus/RTU Cable Length

A Modbus/RTU bus line has limitations which shall not be exceeded, otherwise the communication might not be stable.

- The maximum total bus length must not exceed 1200 m.
- The stub length to each node must not exceed 30 cm.

See the picture below for details.




9.3.2.2 Modbus/RTU Wiring and Cable Type

To ensure a stable communication a twisted-pair bus cable must be chosen to set up the Modbus/RTU communication.

- Bus-cable specifications must follow the EIA485 Standard, must be twisted pair and shielded, for example 2 x 2 x 0.22 mm², Li-2YCY (A553 0123).
- The shield must be connected at one end to the master GND connection.
- At the end of the bus, a 120 Ohm resistor should be placed a termination resistor.


See the below picture for details.



9.3.2.3 Create Daisy-Chain using RS-485 Splitter

To connect the S415 OEM to the daisy-chain, the RS-485 splitter (A554 3310) and the M8 to M12 converter cable (A553 0161) are needed.

Furthermore place a M12 termination resistor (C219 0055) at the last splitter in the daisy-chain, as show in the figure below.



าเม

.570


Remark: The S331 can maximum provide 10 W power to the connected devices. If more power is required a separate power supply is needed.

9.3.2.4 Topology of Modbus/RTU Daisy-Chain

The recommended bus topology is to connect devices as a daisy-chain. Other connection topologies are not recommended and should be avoided.


Make sure that at the end of the bus line, the termination resistor of 120 Ohm is placed to avoid interferences.

Recommended connection of Modbus/RTU salves in a daisy-chain Topology.



Avoid a connection of slaves to the master in ring or star topology.





Avoid a star topology

Avoid a ring topology

9.4 M-Bus Output

Communication parameters

Primary Address	: 1
Secondary Address	: 8-digit serial number of the device
Manufacturer Code	: 0x15C4
M-Bus version	: 1
Baud rate	: 2400
Response delay (ms)	: 7
Response timeout (ms)	: 100
Receive timeout (ms)	: 500


Value register


M-Bus Addr.	Description	Data bytes
1	Total consumption	4-byte
2	Flow	4-byte
3	M-Bus status	4-byte

9.5 Connection between S415 OEM Outputs and Customer Equipment

This section provides figures to show how outputs supported by the S415 OEM connect with the customer equipment.

In the following figures, the **SUTO Instrument** indicates the S415 OEM.





10 Configuration

To change any settings on the S415 OEM, download and install the mobile App **S4C-FS** from the Google Play store or the SUTO website. This App works on any mobile phone with Bluetooth supported.

<	Onli	ne	
0			100%
പ്പം	Flow: 1.	4 I/min	
	Consumption: 967:	295 mª	
l	Temperature:		
ø	Pressure:		
Onli) Ç	} Igs	System

To be allowed to change settings, the App needs to scan the QR code attached on the side of the device head or on the calibration certificate. This ensures that only authorized users can access the device settings. For more information about parameter settings and operating instructions, see the *S4C-FS Instruction and operation manual*.



ATTENTION!

Changes on the settings may lead to wrong measurement results! Contact manufacturer in case you are not familiar with the settings.

11 Calibration

The instrument is calibrated ex work. The exact calibration date is printed on the certificate which is supplied together with the instrument. The accuracy of the instrument is regulated by the on site conditions, parameters like oil, high humidity or other impurities can affect the calibration and furthermore the accuracy. However we recommend to calibrate the instrument at least once per year. The calibration is excluded from the instruments warranty. For this please contact the manufacturer.

12 Disposal or Waste



Electronic devices are recyclable material and do not belong in the household waste.

The device, the accessories and its packing must be disposed according to your local statutory requirements. The dispose can also be carried by the manufacturer of the product, for this please contact the manufacturer.

13 Appendix A - Specifications

13.1 Flow Ranges

The measuring ranges of air are stated under the following conditions:

- Standard flow in air
- Reference pressure: 1000 hPa
- Reference Temperature: +20°C

Unit: **I/min**

	DN8		DN15		DN20		DN25		DN32	
	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
Standard range (S)	50	250	20	1000	40	2000	70	3500	120	6000
Low range (L)	1	50	4	200	8	400	14	700	24	1200

The measuring ranges of N_2 are stated under the following conditions: 0°C and 1013.25 hPa

Unit: I/min

	DN8		DN15		DN20		DN25		DN32	
	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
Standard range (S)	4.44	222	17.8	890	35.6	1780	62.2	3110	107	5335
Low range (L)	0.89	44.5	3.56	178	7.12	356	12.4 4	622	21	1067

13.2 Error Code

When an error code shows on the LED display, use the following table to identify the error cause.

Error code	Description
Er. 01	Real time clock failure
Er. 02	ADC failure
Er. 04	EEPROM failure
Er. 08	NAND flash failure
Er. 20	Flow sensor failure
Er. 30	Temperature sensor failure
Er. 40	Bluetooth failure

13.3 Order Table

	Order Table (Air and N ₂ only)								
Order no.	Size	Range	Output	Description					
				S415 OEM Compact Thermal Mass Flow Meter, 3% o.RDG., 24 VDC					
	0			DN8 G inner thread					
E695 415	1			DN15 G inner thread					
	2			DN20 G inner thread					
	3			DN25 G inner thread					
	4			DN32 G inner thread					
		S		Standard range version of S415 OEM					
A1453		L		Low range version of S415 OEM					
A1450			Α	Analogue 4 20 mA, pulse					
A1451			В	Digital Modbus/RTU					
A1452			С	Digital M-Bus					
A1460				Reverse display direction					



Accessories						
Order no.	Description					
A553 0161	M8 female to M12 male converter cable, 10 cm					
A554 3310	RS-485 splitter T, with 3 x M12 connectors to connect RS-485 devices to a bus.					
A554 0109	Mains power supply 100-240 VAC / 24 VDC, 0.5 A, 2 m cable with M8 connector					
A553 0137	Connection cable S415 OEM/S418 to S551, 5 m					



SUTO iTEC GmbH

Grißheimer Weg 21 D-79423 Heitersheim Germany

Tel: +49 (0) 7634 50488 00 Email: <u>sales@suto-itec.com</u> Website: <u>www.suto-itec.com</u>

SUTO iTEC Inc.

5460 33rd St SE Grand Rapids, MI 49512 USA

Tel: +1 (616) 800-7886 Email: <u>sales.us@suto-itec.com</u> Website: <u>www.suto-itec.com</u>

All rights reserved $\ensuremath{\mathbb{C}}$

SUTO iTEC (ASIA) Co., Ltd.

Room 10, 6/F, Block B, Cambridge Plaza 188 San Wan Road, Sheung Shui, N.T. Hong Kong

Tel: +852 2328 9782 Email: <u>sales.asia@suto-itec.com</u> Website: <u>www.suto-itec.com</u>

> Modifications and errors reserved S415 OEM_im_en_2023-1